

AFS 44-003-10002
APCI 0
ATPI 66- Breakdown Notice
DTA 020528

JUN 03 2002

Air Protection Division (3AP22)

ED 002508A 00000929-00001

NOTICE OF BREAKDOWN OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 02-0062
2. Date & Time of Breakdown: Date: 05/25/02 Time: 1100 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: #20 Battery Igniter Flare
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: The #20 Battery Igniter Flare was unavailable for service while replacing the wiring that leads to the mercooid switch. There was no increase in emissions.
8. Identification of Emissions:
 - A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
No environmental impact.
 - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). N/A
 - C. Amount of each type emitted (or likely to be emitted).
N/A
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The wiring was repaired and the Igniter Flare was available for service.
10. Facility back in operation - Date: 05/25/02 Time: 1700 hours

Signature

Coleen M. Davis
Coleen M. Davis

Date

5/28/02

Environmental Control Engineer

Phone: 233-1015